

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-07863
Name of Facility: Coconut Grove El.
Address: 3351 Matilda Street
City, Zip: Miami 33133

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: MDCPS
Person In Charge: MDCPS Phone: (786) 275-0400
PIC Email:

Inspection Information

Purpose: Routine
Inspection Date: 6/1/2026

Begin Time: 12:45 PM
End Time: 02:30 PM

Additional Information

FEMALES 253
MALES 257

CENSUS 510

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>IN</u> 15. Shower Facilities	<u>IN</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>IN</u> 16. Showers Water Temperatures	<u>IN</u> 24. Changing Station & Mats
<u>IN</u> 5. Maintenance & Repair	WATER SUPPLY	<u>IN</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>IN</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>IN</u> 27. Animal Maintenance/Aggressive
<u>OUT</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>IN</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>IN</u> 29. Other

Marking Key: *IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation*

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Satisfactory

Email Address(es): daniaalvarez@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #9. Mechanical Ventilation
Observed accumulation of dust around mechanical vents of restroom in classroom. Clean and disinfect vents.
CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.

Inspection Conducted By: Javon Johnakin (27326)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Dania Alvarez
Date: 6/1/2026

Inspector Signature:

Handwritten signature of the inspector, appearing as "AA".

Client Signature:

Handwritten signature of the client, appearing as a stylized "V".